



INSTALLATION AND MAINTENANCE INSTRUCTIONS

ALUMINIUM FILTER REGULATOR

SIZE: 1/4", 3/8" & 1/2"

**SERIES
641**

These operating instructions are delivered with each product. Malfunctions, damage or injury may occur if these instructions are not followed.

Description

Series 641 Air Filter Regulators are designed for use in potentially explosive atmospheres caused by gases, vapors, mists and/or dusts as per ATEX Directive 2014/34/EU and standards EN ISO 80079-36. UKSI Regulation 2016 : 1107 (as amended by UKSI 2019:696)- Annex 3A, Part 1 after ATEX directive and BS EN ISO 80079-36 (2016)

Classification (Zone 1 and 21): II 2 G Ex h IIC T5 Gb, II 2 D Ex h IIIC T5 Db
The Classification temperature depends on the ambient temperature. These regulators are made of external metal parts & internal with plastic/metal parts.

Startup and maintenance are to be performed as detailed below.

General

This component is not a safety accessory. It is intended only for the compliant use either as an individual component or incorporated in an apparatus, machinery and installations. Filter Regulators are designed to be operated in accordance with the limits specified in the nameplate or as specified in this document. All applicable directives, legislations, orders and standards, as amended from time to time, as well as state-of-the-art practices and procedures must be observed for intended scope of application of the product. Where applicable take all appropriate measure to ensure the requirements are met. This device complies with the essential safety requirements of the EU PED 2014/68/EU. Declaration of conformity is available on request.

All assembly, operation, use and maintenance must be performed by qualified, authorized personnel. Personnel working with the components must be familiar with the applicable safety and regulations relating to the components, apparatus and machinery installations. In case of problems, please contact ASCO or one of its authorized representatives in your region.

General Operating Specifications

Fluid: Instrument air

Ambient Temperature: For manual drain: the temperature range should be within -40° C to + 90° C (-40°F to +194°F); For Auto drain: the range should be within 0°C to + 90°C (32°F to +194°F).

Inlet Pressure: Do not exceed the maximum operating pressure 20 bar(290psi) for manual drain FR, 11bar(160psi) for auto drain FR.

Installation

Check the preliminary storage conditions required for the component. They must be in accordance with the product's specifications.

Carefully remove the Filter Regulator from the packaging.

Power off and depressurize the apparatus, machinery or installation designed to receive the FR.

Install the FR near where the air is to be used.

Install ASCO pressure gauge comes accessory on the gauge port. & Do Not modify the device.

Make sure that the fluid is compatible with the materials it contacts.

Operator or user must ensure that the gas group corresponds to the product's classification.

Check Nameplate for correct catalog number, pressure, temperature and service. Never apply incompatible fluids or exceed pressure rating of the regulator.

The installer must install the air filter regulator at the user's location in accordance with the requirements specified in Directive 99/92/EC.

POSITIONING

⚠ For optimum life and performance, the FR should be mounted vertically upright (Max. Inclination 5°).



ASCO NUMATICS INDIA Pvt Ltd.,
Plot No P45, 8th Avenue, Mahindra world city
Chengalpattu, Kanchipuram
Tamil nadu- 603002, India

FORM NO: 551461-001

REV: AB

ECN: 326819

PAGE NO: 1





INSTALLATION AND MAINTENANCE INSTRUCTIONS
ALUMINIUM FILTER REGULATOR
SIZE: 1/4", 3/8" & 1/2"

SERIES
641

FR DISASSEMBLY

1. Disassemble FR in an orderly fashion using exploded views for identification and placement of parts. Refer to figure 1.
2. Remove bowl by unscrewing it from body and the bowl seal
3. Unscrew the filter assembly by hand itself
4. Carefully unscrew the bowl baffle in filter assembly and remove filter element for cleaning
5. For normal maintenance(cleaning) it is not necessary to remove the poppet assembly. However, if poppet assembly removal is required, just pull it out of the body.
6. Remove the manual drain/auto drain from the bowl
7. Unscrew bonnet from the body to remove bonnet, top spring and diaphragm assembly
8. All parts are now accessible to clean or replacement. If parts are worn or damaged, install a complete ASCO Spare Parts Kit

⚠ Use Metal Pipes only for IN and OUT connection. For Non-Metallic / Non – conductive pipes that requires EARTHING OR GROUNDING can be given in any one of the front side/back side M5 mounting hole shown as - [➡]

- Service Notice -

When installing a new ASCO spare parts kit, the parts supplied are shown in Figure. A. The parts supplied are new and a direct replacement for the present parts provided all new parts are installed.

CAUTION: To ensure proper valve operation, install all parts supplied in ASCO Spare Parts Kit. Do not mix old and new parts.

FR REASSEMBLY

1. Lubricate all gaskets with CERAN LT lubricant or an equivalent low temperature silicone fluid.
2. Add a layer of NEVERSEEZ – 160S on all screw threads
3. If removed, install poppet assembly in body. Apply a small amount of NEVERSEEZ – 160S to filter sub assembly threads. Hand tight the assembly as far as possible. No special tool is required to provide torque
4. Install diaphragm assembly, springs, spring disc and bonnet on top. Screw tight bonnet on top of the body.
5. Replace manual drain/auto drain on bowl and reassemble the unit by screwing bowl on bottom side of the body.
6. Install FR in vertical position.



ASCO NUMATICS INDIA Pvt Ltd.,
Plot No P45, 8th Avenue, Mahindra world city
Chengalpattu, Kanchipuram
Tamil nadu- 603002, India

FORM NO: 551461-001
REV: AB
ECN: 326819
PAGE NO: 2



EXPLODED VIEW





FIG. 1

TEMPERATURE CLASSIFICATION



TECHNICAL DETAILS	641
TEMP, STANDARD, NBR (°C)	-40 TO +90
TEMP, FKM (°C)	-20 TO +80
TEMP, LOW TEMP (°C)	-52 TO +90
TEMP, AUTO DRAIN (°C)	+0 TO +90



FIG. 2: FR SECTIONAL VIEW

FIG. 4: LABEL

MOUNTING

FIG. 5: ASSEMBLE VIEW



FIG. 6: DISASSEMBLED VIEW

GAUGES

FIG. 7: WIHOUT GAUGE




FIG. 8: WITH SS GAUGE



FIG. 9: WITH NON – SS GAUGE

TAMPER PROOF

ASSEMBLY (FIG 11)



FINAL ASSEMBLY (FIG 10)



DIS ASSEMBLY (FIG 12)


FIG. 13: PARTIAL SECTION
VIEW

FIG 14

T- HANDLE**REGULAR****T - HANDLE TYPE**CLOCKWISE TO SET PRESSURE
(FROM TOP VIEW)

FIG. 15



FIG. 16

DISASSEMBLY

ANTI - CLOCKWISE



CLOCKWISE

FIG. 17

ASSEMBLY

CLOCKWISE



ANTI - CLOCKWISE




FIG. 18



To disassembly (From top view):

- Turn in clockwise direction to loosen the bowl from the body
- Turn in anticlockwise direction to remove bonnet from the body

To assembly (From top view):

- Tighten the bowl in anticlockwise direction to assembly it with body
- Turn in clockwise direction to assembly bonnet with the body

DRAINS		METAL MANUAL DRAIN (Brass/stainless steel)	<ul style="list-style-type: none"> • TEMPERATURE: -40°C ... +90°C • Min. INLET PRESSURE (P1 Min.): 0 Bar • Max. INLET PRESSURE (P1 Max.): 20 Bar 	
		Automatic Drain NC	<ul style="list-style-type: none"> • TEMPERATURE: +0°C ... +90°C • Min. INLET PRESSURE (P1 Min.): 2.5 Bar • Max. INLET PRESSURE (P1 Max.): 11 Bar 	  <div style="display: flex; justify-content: space-around; width: 100%;"> STANDARD WITH ADAPTOR </div>

FILTERS	PE	Filtration	5 µm	25 µm	40 µm	
		Colour	White	Yellow	Green	
Bronze	Bronze	Filtration	5 µm	25 µm	40 µm	
Stainless Steel		Filtration	5 µm	25 µm	40 µm	

FILTER

641 SERIES**USABLE IN ATEX ZONES**

FIG. A




FIG. B



INSTALLATION AND MAINTENANCE INSTRUCTIONS
ALUMINIUM FILTER REGULATOR
SIZE: 1/4", 3/8" & 1/2"

SERIES
641

This product category does not fall within the scope of the ATEX 2014/34 / EU directive: the risk analysis according to the EN ISO 80079-36 standard has shown that no potential source of ignition specific to the products are effective. These products can be used in specific explosion zones 1 and 21 in compliance with our installation instructions:

* List of affected components

- Mounting components
- Assembly and connection components
- Mechanical accessories
- Filter

These **conditioning units of compressed air and their accessories** are capable for use in explosive atmospheres in the form of gas, steam, mists and dust.



SPECIAL CONDITIONS FOR SAFE USAGE:

Risk from electrostatic charges

Prevent electrostatic charging of external insulating surfaces by using the appropriate installation and cleaning measures. To clean external insulating surfaces, use a damp cloth.

Connect the conditioning units to the earth.

When combined with other conditioning units, ensure that all metallic and conductive parts are always interconnected and linked to the earth to avoid significant electrostatic charges being created.

The earth is connected to the unit or to the combination of conditioning units by the downstream and upstream use of metal pipes connected to the earth. If the pipes are non-conductive, earth connection should be performed by the assembly and/or fixing devices adapted to the ATEX products.

Installation, commissioning and servicing and maintenance

These operations may only be carried out by authorised personnel and in accordance with the usage instructions.

Only carry out maintenance in zones where there is no explosive atmosphere.

If during maintenance it is established that wearing and spare parts need exchanging, contact an ASCO Numatics or AVENTICS reseller.

Any modification of the product with parts not supplied by the manufacturer will invalidate the certification.

Filter equipped with a metallic bowl: (see fig. B)

When replacing a filter element saturated by the filter, proceed as described below:

- Remove the Bowl (4) from the body (3)
- Remove the filter element and replace with a new one
- Assemble the bowl (4)



ASCO NUMATICS INDIA Pvt Ltd.,
Plot No P45, 8th Avenue, Mahindra world city
Chengalpattu, Kanchipuram
Tamil nadu- 603002, India

FORM NO: 551461-001
REV: AB
ECN: 326819
PAGE NO: 12

